

ADDENDUM #2

To: All Proposal Holders

Date: July 29, 2026

From: Michelle Koslap, Project Coordinator
SEDA-Council of Governments
201 Furnace Road
Lewisburg, PA 17837
570-524-4491

Project: **Austin Borough Water Plant Improvements – Electrical Upgrades**

This Addendum forms a part of the Request for Quotes (RFQ) and modifies the original RFQ, dated July 21, 2026, as noted below. All proposers must sign and return the attached Acknowledgement of Receipt of Addendum. Acknowledgement of Receipt is required to ensure consideration of the proposal. Failure to do so may subject the proposer to disqualification.

This Addendum consists of the following items:

The following question was received regarding the RFQ:

Q: Are the engineering services limited to the Water Treatment Plant located at 57 Garman Lane, or does the scope also include any remote facilities connected to the plant's control system, such as well sites, booster pump stations, storage tanks, or other remote telemetry (RTU) locations?

A: The only off-site location where engineering and electrical work may be required is the storage tank, located approximately one-half mile from the water treatment plant. The site contains a SCADA control panel with a radio and antenna for communication with the water treatment plant. No other remote facilities are included in the project scope.

Acknowledgement of Receipt of Addendum

We hereby acknowledge and confirm receipt of **ADDENDUM #2** regarding the **Austin Borough Water Plant Improvements – Electrical Upgrades** and have attached this Addendum to our copy of the RFQ.

Company Name:

By:

Title:

Date:
