

ADDENDUM #2

To: All Proposal Holders

Date: July 21, 2022

From: Tyler Dombroski, Director of Community Development
SEDA-Council of Governments

Project: **SULLIVAN COUNTY EMERGENCY TOWER**

The following additional information has been provided as a result of additional questions received concerning the project:

- NEPA environmental reviews have been waived for American Rescue Plan Act funded projects. This project is fully financed through American Rescue Plan Act funding.
- The county will work with the selected consultant to identify specific antennas and radio equipment to be utilized for the project.
- The county does not have a preference concerning a generator manufacturer. However, all of the county's current towers use a Generac generator fueled by propane. An alternative solution would need to be able to be supported and maintained via a local provider.
- The county wishes to have a freestanding tower constructed. However, if logistical issues such as steel lead times make a monopole more expeditious to delivery within grant timeframes, then the county would be open to that as a proposed alternative.
- The county expects that the driveway access to the project site will have a designated car turnaround area.
- The deadline for proposers to submit questions will be Tuesday, July 21, 2022, at 4:00 PM Eastern Daylight Time.
- This addendum shall be signed and submitted with any proposal.

Name:

Date: